

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WEST CARROLL WATER)	
DISTRICT FOR A DEVIATION FROM THE)	
MINIMUM WATER STORAGE REQUIREMENT OF)	CASE NO. 90-089
807 KAR 5:066, SECTION 5(4))	

O R D E R

By application received April 9, 1990, West Carroll Water District ("West Carroll") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. West Carroll states in its application that its average daily water usage, including unaccounted-for water, is approximately 1,422,000 gallons, and that it has only two storage tanks with a total capacity of 247,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. West Carroll is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, West Carroll should be given until July 1, 1993 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).

IT IS THEREFORE ORDERED that:

1. West Carroll be and it hereby is given until July 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. West Carroll shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1993.

Done at Frankfort, Kentucky, this 9th day of May, 1990.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director